

<b>Test Code Sheet Number</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>1</b>	<b>10</b>
-------------------------------	----------	----------	----------	----------	-----------

WBS TEST & ACCEPTANCE CRITERIA PD.

Issue No: 2  
Date of issue: April 1994

Sheet 1 of 1

TEST CODE SHEET

---

1. **TYPE OF TEST(S)**

Visual inspection - means of operation.

2. **BYELAW REQUIREMENT FOR FITTINGS**

Byelaw 71

Every servicing valve shall be - (a) designed or adapted to operate only by the insertion of a screwdriver or other instrument in a slot on the valve.....

3. **BRITISH STANDARDS OR WATER SPECIFICATION, DEEMED TO SATISFY BYELAW REQUIREMENTS**

(See Water Supply Byelaw Guide)

3.1 Fittings with 'kitemarks' which are deemed to satisfy the requirements of byelaws are listed in the directory.

4. **TEST PROCEDURE**

Note Unless stated otherwise the temperature of the test fluid shall be  $20 \pm 10^{\circ}\text{C}$ .

4.1 Tests applicable to the following fittings-

**VALVES** - servicing  
(not complying with byelaw 64 or for use where pressure exceeds 1 bar).

---

(A) **SERVICING VALVES** (Derived from BS 6675, Section 2, Clause 6.2)

**TEST METHOD**

Inspect the fitting to establish the means of the operation intended to be used.

5. **ACCEPTANCE CRITERIA**

The only means of operation possible shall be by the insertion of a screwdriver or other instrument in the slot on the valve.