

Test Code Sheet Number	2	2	1	2	6
------------------------	---	---	---	---	---

**TEST CODE SHEET CLARIFICATION**

Issue No. 1  
Date of Issue: January 2016

The following information should be read in conjunction with the Test Code Sheet 2212.6 It is intended to aid the Test Inspector in clarifying the test and acceptance criteria requirements.

NOTE: This clarification applies to **TCS 2212.6 : Issue 4**

**Correction to dimension h, schematic should state 150-200mm in accordance with the test procedure.**

(3) Fit the transparent sight tube of suitable length to the shower hose outlet connection, avoiding kinking. Submerge the other open end in water, the surface of which being 150mm to 200mm below the bath outlet of the tap under test.

Dimension h =150mm – 200mm




Figure 75

Revision History					
No.	Page No.s	Rev. No.	Description of Change	Author	Effective Date
1					