

TEST CODE SHEET CLARIFICATION

The following information should be read in conjunction with Test Code Sheet 6001.1. It is intended to aid the test laboratories and manufacturers in clarifying the test and acceptance criteria requirements.

NOTE: This clarification applies to **TCS 6001.1 Issue 7 Clause (A)**

ACCEPTANCE CRITERIA

Marking requirements for braided flexible hoses

Ferrule/ Crimped connector must be permanently marked with:

MUST HAVE (BOTH OF THESE ARE ESSENTIAL)

- 1.) WRAS logo or name
- 2.) Year of manufacture

AND IN ADDITION MUST HAVE ONE OF THE FOLLOWING

- 1.) Manufacturer name or logo OR
- 2.) Factors name or logo OR*
- 3.) Tradename*

Where the braided flexible hose is for a tap connector the marking must be at the end not connected to the tap, if the flexible hose incorporates a ball valve or check valve the marking must be at that end.

Marking requirements for unbraided flexible hoses

Ferrule/ Crimped connector must be permanently marked with:

MUST HAVE (BOTH OF THESE ARE ESSENTIAL)

- 1.) WRAS logo or name
- 2.) Year of manufacture

AND IN ADDITION MUST HAVE ONE OF THE FOLLOWING

- 1.) Manufacturer name or logo OR
- 2.) Factors name or logo OR*
- 3.) Tradename*

Alternatively, the hose can be marked with:

MUST HAVE (BOTH OF THESE ARE ESSENTIAL)

- 1.) WRAS logo or name
- 2.) Year of manufacture

AND IN ADDITION MUST HAVE ONE OF THE FOLLOWING

- 1.) Manufacturer name or logo OR
- 2.) Factors name or logo OR*
- 3.) Tradename*

Hoses longer than 500mm must be marked every 200mm.

NOTE: Shower hoses must be marked in accordance with TCS 6001.1,
http://www.wras.co.uk/PDF_Files/Regulator%20specs/6001.1.pdf

Version 1.2

Issued 1st January 2012.

Re-issued 26th November 2013 with updated information*.

Re-issued 3rd June 2016 with title.